



NOTE:  
 CONSTRUCT APPROPRIATE DIAMETER  
 AND DEPTH MJ X MJ OFFSET TO  
 PROVIDE 18" MINIMUM CLEARANCE  
 BETWEEN WATER MAIN AND SEWER

## WATER MAIN OFFSET DETAIL

NO SCALE

APPROVED DATE: 7-26-02  
 DETAIL: 825-2A

City of Eaton Rapids

September, 2002